

PNEUMATIC INSPECTION DEVICE TO TEST INSULATING GLOVES

Reference : OE 0305



Item name	PNEUMATIC INSPECTION DEVICE TO TEST INSULATING GLOVES
Bar code	3700461471483
Introduction	For checking the tightness and integrity of insulating gloves prior to use. The operator places the glove on the tester, inflates the glove using the hand pump and dips the assembly in water to perform the test.
Specifications	Specifications : - pump: manual - integrated soft valve - 2 "glove-holding" elastic rings - dimensions: 135x135x125mm
Warranty period	No warranty (consumable)
Length (mm)	130 mm
Width	130 mm
Height	125 mm
Tariff code	Tariff Normal (TN)
Warranty Procedure	NO



CLAS EQUIPEMENTS
83, chemin de la CROUZA
73800 CHIGNIN
France

Tel : +33 (0) 4 79 72 62 22
Fax :

Monday to Friday - From 8 to 12h
and from 13h30 to 17h30 (16h30 on
Friday)